

Subject: Statement of Flame Retardancy – Blackback contrast

Waddinxveen, 29 March 2021

Dear Customer,

With this document Texo Trade Services BV declares that the result of the inspection made according to DIN EN 13501-1:2010 has shown that F175FR02 meets the classification of polyester with a flame retardant treatment.

The holder of the certificate, who has issued a conformity declaration according to DIN EN 13501-1:2010, is under an obligation to use the B – s1, d0 mark only in conjunction with the sample initially tested. The conformity is verified by audits.

Conclusion of the test: The tested sample meets the low flammability requirements of Class B – S1. D0 of building materials under DIN EN 13501-1:2010.

This authorization is filed under number PK1-01-17-029-E-0

Kind regards,

**TTS** **Texo Trade Services BV**  
Oostbaan 601  
2841 ML Moordrecht  
The Netherlands  
T +31 182 62 39 44  
printable textiles &  
transfer printing media  
www.texo-trade.com

Simon Supusepa  
Quality Manager  
Texo Trade Services BV

